

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7770-0662:101

Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: United Electric Controls, 180 Dexter Ave., Watertown MA 02472
Contact: *Gary Walkeapaa (617) 926-1000 Fax (617) 926-2568

DESIGN: Models J120X-5355, J120X-5835, H122P-5355 and H122P-5835 pressure switch. Suitable for use in Class I, Groups B, C and D; and Class II, Groups E, F and G; and Class III hazardous locations. Refer to listee's data sheet for detailed product description and operational considerations).

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a pressure switch for use in automatic fire sprinkler systems.

NOTE: Formerly 7610-0662:101

*Rev. 06-22-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager